

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. KDLL/24/651

Dated: 28/06/2024

It is certified that an inspection team headed by Santa Sikha Dutta, AEE (PHE)

(Name of Officers with designation) from GUWAHATI DIV. I PHED

Inspected the The down town school, Hatishila, Chandrapur Road, Guwahati.

(Name & Address of the school) on ..... (date of inspection) and on the basis of Water Test

Report (Attached) bearing no. KDLL/24/651 dated 27/06/2024

of District Level Laboratory (PHED Lab) certified that the parameters

tested are in safe range as per IS 17025. (Name of school) has safe drinking water facilities for

the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till June, 2025.

Signature with Seal: Santa Sikha

Name : SANTA SIKHA DUTTA

Designation : AEE (PHE)

Name & Address of the Office/Department: O/o THE EE(PHE)

GUWAHATI DIV. I, BANUNIM Aidam

GUWAHATI - 21

To

The Principal

The down town School, Hatishila.

(Name & Address of the Institution)

**In Charge**  
**District Level Laboratory**  
**Kamrup (PHE) Department**  
**Guwahati-21**





## DISTRICT LEVEL LABORATORY (PHED), KAMRUP

Address: Bamunimaidam, Guwahati 21

Email ID: phe.kamrup@gmail.com, Ph No: 0361-225641

### Test Report

UID No.: TC97762300000000651F

Issue Date: 28/06/2024

Customer Reference No: KDLL/24/651

Issue No: 651

Customer Name & Address: The Down Town School

Sample collected on dated: 25/06/2024

Sample Collected by: Nikhilesh Sarma

Sample Location: The Down Town School, Hatisila, Chandrapur Road

Date of Analysis started: 26/06/2024

Temp: 25.8°C Humidity: 50.2%

Test Sample: Drinking Water (Tank)

Customer Contact No: - 9435148739

Sample received on dated: 25/06/2024

Quantity: 1000 ml

Sample Condition: Good Condition at 4°C

Date of analysis completed: 27/06/2024

### RESULTS

Sr. No.	Parameter	Protocol Used	Results	IS: 10500:2012 (Second Revision)		Unit
				Desirable limit	Max. Permissible limit (in absence better alternate source)	
1	Colour	IS: 3025 (Part 4)	≤5	5	15	Hazen
2	Taste	IS: 3025 (part 8)	Agreeable	Agreeable	Agreeable	
3	Turbidity	IS: 3025 (Part 10)	0	1	5	NTU
4	pH	IS: 3025 (Part 11)	6.92	6.5 - 8.5	No relaxation	pH unit
5	TDS	IS: 3025 (Part 16)	80	500	2000	mg/L
6	Chloride	IS: 3025 (Part 32)	10.14	250	1000	mg/L
7	Total Alkalinity	IS: 3025 (Part 23)	12.6	200	600	mg/L
8	Total Hardness	IS: 3025 (Part 21)	75.6	200	600	mg/L
9	Calcium (as Ca)	IS: 3025 (Part 40)	21.88	75	200	mg/L
10	Magnesium	APHA (24th Ed) 3500 Mg B	13.05	30	100	mg/L
11	Total Iron	APHA 3500 (24th Ed) Fe B	0.35	1	No relaxation	mg/L
12	Arsenic	APHA 3500 (24th Ed) As B	-	0.01	No relaxation	mg/L
13	Free Residual Chlorine	IS 3025 (Part 26)	-	0.2	1	mg/L
14	Fluoride	APHA (24rd Ed) 4500 F	0.630	1	1.5	mg/L
15	Nitrate	APHA (24rd Ed) 4500	7.006	45	No relaxation	mg/L
16	Sulphate	IS 3025 (Part 24)	10.124	200	400	mg/L
17	Odour	IS 3025 (Part 5)	Agreeable	Agreeable	Agreeable	

#### Notes:

BDL : Below Detection Limit

- The results given above are related to the sample as received and tested in this laboratory. Reliability of sample lies with the sender.
- The test report cannot be regenerated or re-produced in whole or in part without written permission of Laboratory.
- The test report cannot be used for any publicity or any legal purpose.
- The test samples meant for chemical analysis will be disposed of after 15 days from the date of issue of test report unless until specifically requested by the customer for retaining over a longer period.

END OF TEST REPORT

*Sambasree*  
In Charge  
District Level Laboratory  
Kamrup (PHE) Department  
Guwahati-21

Authorized By,  
*[Signature]*  
Nova Debnath  
Quality Manager  
**QUALITY MANAGER**  
**DLL(NABL), PHED, ASSAM**  
Bamunimaidam, Guwahati-21



GOVERNMENT OF ASSAM  
OFFICE OF THE JOINT DIRECTOR OF HEALTH SERVICES  
KAMRUP METROPOLITAN DISTRICT SATPUKHURI, UZANBAZAR, GUWAHATI-1

No. Esstt./Jt DHS(M)/Sanitation/2023-24/ 6251 /

Dated 13/3/24

CERTIFICATE OF HEALTH AND HYGIENE

NAME AND ADDRESS OF THE SCHOOL - = THE DOWN TOWN SCHOOL, CHANDRAPUR ROAD, HATHISILA, KHANKAR GAON, KAMRUP METRO.

DATE OF INSPECTION - - - - - :- 12-03-2024

POINT OF OBSERVATION :-

CLEANLINESS IN AND AROUND THE SCHOOL CAMPUS:- CLEAN

SAFE DRINKING WATER - - - - - AVAILABLE

URINAL & LATRINE'S CONDITION AND NUMBER OF TOILETS - - - - - GOOD, SUFFICIENT IN NUMBER

DRAINAGE SYSTEM OF THE CAMPUS - - - :- GOOD

GENERAL CONDITION OF THE SCHOOL - - - :- GOOD

RATIO OF STUDENTS TO TEACHER - - - - - MAINTAINED

FIRE SAFETY MEASURES - - - - - MAINTAINED.

AVAILABILITY OF THE FIRST AID BOX - - - :- AVAILABLE

In view of the above, this is to certify that the THE DOWN TOWN SCHOOL, CHANDRAPUR ROAD, HATHISILA, KHANKAR GAON, KAMRUP METRO is maintaining good health and hygiene in and around the School.

The above Certificate is valid for the year 2024-2025.

*13.3.2024*

Joint Director of Health Services  
Kamrup Metropolitan District,  
Uzanbazar, Guwahati-1.

Joint Director  
Kamrup Metropolitan District

N B - When necessary Inspection may be visited at any time for hygiene and Sanitation Maintenance.



*[Signature]*

Principal

the down town School